

ANALYSIS INFORMATION

REPORTED TO PROJECT Ootischenia Improvement District
Weekly Microbiological Analysis

WORK ORDER REPORTED 5080867
Aug-20-15

Analysis Description	Method Reference	Technique	Location
Alkalinity in Water (Total)	APHA 2320 B*	Titration with H2SO4	Kelowna
Anions in Water by IC	APHA 4110 B	Ion Chromatography with Chemical Suppression of Eluent Conductivity	Kelowna
Colour, True	APHA 2120 C	Spectrophotometry (456 nm)	Kelowna
Conductivity in Water	APHA 2510 B	Conductivity Meter	Kelowna
Cyanide, Total in Water	APHA 4500-CN- C / APHA 4500-CN- E	Distillation / Colorimetry	Kelowna
E. coli (CCA)	APHA 9222*	Membrane Filtration / Chromocult Agar	Kelowna
Hardness (as CaCO3)	APHA 2340 B	Calculation	N/A
Mercury, total by CVAFS	EPA 245.7*	BrCl2 Oxidation / Cold Vapor Atomic Fluorescence Spectrometry (CVAFS)	Richmond
pH in Water	APHA 4500-H+ B	Electrometry	Kelowna
Solids, Total Dissolved	APHA 1030 E	Calculation	N/A
Total Coliforms (CCA)	APHA 9222*	Membrane Filtration / Chromocult Agar	Kelowna
Total Recoverable Metals	APHA 3030E* / APHA 3125 B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma Mass Spectrometry (ICP-MS)	Richmond
Transmissivity at 254 nm	APHA 5910 B	Ultraviolet Absorption	Kelowna
Turbidity	APHA 2130 B	Nephelometry	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Method Reference Descriptions:

APHA Standard Methods for the Examination of Water and Wastewater, 22nd Edition, American Public Health Association/American Water Works Association/Water Environment Federation
EPA United States Environmental Protection Agency Test Methods

Glossary of Terms:

MRL Method Reporting Limit
< Less than the Reported Detection Limit (RDL) - the RDL may be higher than the MRL due to various factors such as dilutions, limited sample volume, high moisture, or interferences
% T Percent Transmittance
CFU/100 mL Colony Forming Units per 100 millilitres
CU Colour Units (referenced against a platinum cobalt standard)
mg/L Milligrams per litre
NTU Nephelometric Turbidity Units
pH units pH < 7 = acidic, pH > 7 = basic
µS/cm Microsiemens per centimetre

Standards / Guidelines Referenced in this Report:

Guidelines for Canadian Drinking Water Quality (Oct 2014)
Website: http://www.hc-sc.gc.ca/ewh-semt/alt_formats/pdf/pubs/water-eau/sum_guide-res_recom/sum_guide-res_recom-eng.pdf

Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user

SAMPLE ANALYTICAL DATA

REPORTED TO PROJECT Ootischenia Improvement District
Weekly Microbiological Analysis

WORK ORDER REPORTED 5080867
Aug-20-15

Analyte	Result / Recovery	Standard / Guideline	MRL / Units Limits	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------------	----------	----------	-------

Sample ID: Well 2 (5080867-01) [Water] Sampled: Aug-12-15 14:15

Anions

Chloride	1.83	AO ≤ 250	0.10 mg/L	N/A	Aug-15-15	
Fluoride	< 0.10	MAC = 1.5	0.10 mg/L	N/A	Aug-15-15	
Nitrate as N	0.241	MAC = 10	0.010 mg/L	N/A	Aug-15-15	
Nitrite as N	< 0.010	MAC = 1	0.010 mg/L	N/A	Aug-15-15	
Sulfate	9.0	AO ≤ 500	1.0 mg/L	N/A	Aug-15-15	

General Parameters

Alkalinity, Total as CaCO3	42	N/A	1 mg/L	N/A	Aug-14-15	
Colour, True	< 5	AO ≤ 15	5 CU	N/A	Aug-14-15	
Conductivity (EC)	109	N/A	2 µS/cm	N/A	Aug-14-15	
Cyanide, Total	< 0.010	MAC = 0.2	0.010 mg/L	Aug-18-15	Aug-19-15	
pH	7.24	6.5-8.5	0.01 pH units	N/A	Aug-14-15	HT2
Turbidity	0.2	OG < 0.1	0.1 NTU	Aug-14-15	Aug-14-15	
UV Transmittance @ 254nm	99.1	N/A	0.1 % T	N/A	Aug-14-15	

Calculated Parameters

Hardness, Total (Total as CaCO3)	47.1	N/A	5.0 mg/L	N/A	N/A	
Solids, Total Dissolved	58.8	AO ≤ 500	2.0 mg/L	N/A	N/A	

Total Recoverable Metals

Aluminum, total	< 0.05	OG < 0.1	0.05 mg/L	Aug-18-15	Aug-20-15	
Antimony, total	< 0.001	MAC = 0.006	0.001 mg/L	Aug-18-15	Aug-20-15	
Arsenic, total	< 0.005	MAC = 0.01	0.005 mg/L	Aug-18-15	Aug-20-15	
Barium, total	< 0.05	MAC = 1	0.05 mg/L	Aug-18-15	Aug-20-15	
Beryllium, total	< 0.001	N/A	0.001 mg/L	Aug-18-15	Aug-20-15	
Boron, total	< 0.04	MAC = 5	0.04 mg/L	Aug-18-15	Aug-20-15	
Cadmium, total	< 0.0001	MAC = 0.005	0.0001 mg/L	Aug-18-15	Aug-20-15	
Calcium, total	15.0	N/A	2.0 mg/L	Aug-18-15	Aug-20-15	
Chromium, total	< 0.005	MAC = 0.05	0.005 mg/L	Aug-18-15	Aug-20-15	
Cobalt, total	< 0.0005	N/A	0.0005 mg/L	Aug-18-15	Aug-20-15	
Copper, total	0.004	AO ≤ 1	0.002 mg/L	Aug-18-15	Aug-20-15	
Iron, total	< 0.10	AO ≤ 0.3	0.10 mg/L	Aug-18-15	Aug-20-15	
Lead, total	< 0.001	MAC = 0.01	0.001 mg/L	Aug-18-15	Aug-20-15	
Magnesium, total	2.3	N/A	0.1 mg/L	Aug-18-15	Aug-20-15	
Manganese, total	< 0.002	AO ≤ 0.05	0.002 mg/L	Aug-18-15	Aug-20-15	
Mercury, total	< 0.00002	MAC = 0.001	0.00002 mg/L	Aug-18-15	Aug-19-15	
Molybdenum, total	0.002	N/A	0.001 mg/L	Aug-18-15	Aug-20-15	
Nickel, total	0.002	N/A	0.002 mg/L	Aug-18-15	Aug-20-15	
Phosphorus, total	< 0.2	N/A	0.2 mg/L	Aug-18-15	Aug-20-15	
Potassium, total	1.1	N/A	0.2 mg/L	Aug-18-15	Aug-20-15	
Selenium, total	< 0.005	MAC = 0.05	0.005 mg/L	Aug-18-15	Aug-20-15	
Silicon, total	7	N/A	5 mg/L	Aug-18-15	Aug-20-15	
Silver, total	< 0.0005	N/A	0.0005 mg/L	Aug-18-15	Aug-20-15	
Sodium, total	2.6	AO ≤ 200	0.2 mg/L	Aug-18-15	Aug-20-15	
Uranium, total	< 0.0002	MAC = 0.02	0.0002 mg/L	Aug-18-15	Aug-20-15	
Vanadium, total	< 0.01	N/A	0.01 mg/L	Aug-18-15	Aug-20-15	
Zinc, total	< 0.04	AO ≤ 5	0.04 mg/L	Aug-18-15	Aug-20-15	

SAMPLE ANALYTICAL DATA

REPORTED TO PROJECT Ootischenia Improvement District
Weekly Microbiological Analysis

WORK ORDER REPORTED 5080867
Aug-20-15

Analyte	Result / Recovery	Standard / Guideline	MRL / Limits	Units	Prepared	Analyzed	Notes
---------	-------------------	----------------------	--------------	-------	----------	----------	-------

Sample ID: Well 2 (5080867-01) [Water] Sampled: Aug-12-15 14:15, Continued

Microbiological Parameters

Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	Aug-13-15	Aug-14-15	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	Aug-13-15	Aug-14-15	

Sample / Analysis Qualifiers:
HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.